

Revised 12/12

**SECTION 15059
WELDED STEEL FITTINGS**

PART 1 - REQUIREMENT

1.01 FITTINGS

Fittings shall be fabricated as shown on the contract drawings, and/or as specified in the Special Conditions.

1.02 FLANGES

- A. Steel flanges shall conform to the requirements of Drawing B-288 made a part hereof by reference.
- B. Ring flanges shall be for welding to the pipe unless otherwise noted on the plans.
- C. Screwed flanges, where required, shall be Crane No.556 or approved equal.

END OF SECTION 15059