



- NOTES**
1. CUSTOMER SHALL SUPPLY AND INSTALL A USC APPROVED LEAD FREE BACK FLOW PREVENTION ASSEMBLY (BPA) TO STATE REGULATIONS, APPLICABLE UNIFORM PLUMBING CODE AND SPECIFICATIONS OF WESTERN APPROVED MATERIAL LIST. SELECTED BACK FLOW DEVICE NEEDS TO BE APPROVED BY WESTERN CROSS CONNECTION DEPARTMENT PRIOR TO INSTALLATION.
  2. BPA SHALL BE SIZED TO MATCH THE DIAMETER OF THE SUPPLY METER OR UP TO 1" LARGER IN ACCORDANCE WITH THE UNIFORM PLUMBING CODE.
  3. BPA SHALL BE INSTALLED WITH NO OUTLETS, TEES OR CONNECTION BETWEEN THE METER AND THE BPA. MAINLINE MATERIAL FROM THE DOWNSTREAM SIDE OF THE METER TO THE DOWNSTREAM SIDE OF THE BPA SHALL CONSIST OF BRASS OR COPPER.
  4. BPA SHALL BE INSTALLED AS CLOSE AS PRACTICAL TO THE METER BUT NOT FURTHER THAN 3 FT. UNLESS A VARIANCE IS OBTAINED FROM A WESTERN CROSS CONNECTION CONTROL SPECIALIST PRIOR TO INSTALLATION.
  5. UPON INSTALLATION AND PRIOR TO WATER DELIVERY, THE BPA SHALL BE INSPECTED, TESTED AND CERTIFIED BY AWWA CERTIFIED BACK FLOW TESTER THAT IS LISTED ON THE WESTERN APPROVED BACK FLOW TESTER LIST. COMPLETED TEST REPORTS SHALL BE FORWARDED TO THE WESTERN CROSS CONNECTION CONTROL / BACK FLOW DEPARTMENT.
  6. BACK FLOW CERTIFICATION / TESTING IS REQUIRED ANNUALLY AT A MINIMUM, BUT MAY BE REQUIRED MORE FREQUENTLY IF WESTERN DEEMS NECESSARY. THE CUSTOMER IS RESPONSIBLE TO TEST AND MAINTAIN THE BPA.
  7. ALL PLUMBING ILLUSTRATED IS NOT OWNED, MAINTAINED OR OPERATED BY WESTERN AND IS TO BE IN COMPLIANCE WITH APPLICABLE PLUMBING CODES AND WITH REGULATIONS OF THE WESTERN CROSS-CONNECTION CONTROL DEPARTMENT.
  8. ALL UNDERGROUND PIPES TO BE WRAPPED IN PLASTIC.