



NOTES:

1. COAT ALL BURIED METAL WITH NON-OXIDE GREASE AND POLY PLASTIC WRAP OR TRENTON PRIMER AND POLY PLASTIC WRAP.
2. ALL THRUST BLOCKS TO BE POURED AGAINST UNDISTURBED EARTH. USE CLASS "C" CONCRETE.
3. 8" GATE VALVE CAP BY SOUTH BAY FOUNDRY OR APPROVED EQUAL. MARK: WMWD WATER, PAINTED TRAFFIC BLUE - SHERWIN WILLIAMS OR APPROVED EQUAL.

