



NOTES:

1. ALL MATERIALS FURNISHED TO BE OF THE PIPE PRESSURE CLASS CALLED FOR ON PLANS.
 2. UNLESS NOTED OTHERWISE, ALL THREADS TO BE STANDARD IRON PIPE SIZE THREADS.
 3. GUARD POSTS, AS REQUIRED ON PLANS OR SPECIFICATIONS, SEE STANDARD DRAWING No. W-1520.
 4. CORPORATION STOP AND FITTINGS AT WATER PIPELINE SHALL BE PRIMED WITH NON-OXIDE AND WRAPPED WITH 20 MIL. MINIMUM.
 5. VALVE BOX SHALL BE 8 3/4" DIAMETER BROOKS PRODUCTS No. 1-RT OR EQUIVALENT.
 6. 1/2" DIAMETER x 4" LONG TYPE STAINLESS STEEL ANCHOR BOLT (3 EACH AT 120 DEGREE APART WITH 2-PART EPOXY AND STAINLESS STEEL NUTS AND WASHERS).
- * PER LOCAL AGENCY OR JURISDICTION.



APPROVED DATE: 1/15/2020

Deek Kanwal

DIRECTOR OF ENGINEERING

STANDARD DRAWING
1" OR 2" AIR VACUUM
AND AIR RELEASE
VALVE ASSEMBLY

STD. DWG. NO.
W-0460