



NOTES:

1. APPROVED PRECAST CONCRETE VAULT CARDER 60" DIA GSTA OR 60" NSTA OR EQUAL CONFORMING TO ASTM DESIGNATION C478 AND WITHSTANDING AASHTO/H-20 LOADING.
2. THE PURPOSE OF THIS INSTALLATION IS TO ALLOW FOR RECORDING OF FLOWS IN THE PIPE OVER A PERIOD OF TIME WITH A DEVICE CALLED A PITOT TUBE, WHICH IS INSERTED INTO THE PIPE THROUGH THE CORPORATION STOP.
3. CONCRETE FOOTING MEMBERS TO HAVE REINFORCING BARS.
LONGITUDINAL: 3 #6'S @ 3" SPACING
TRANSVERSE: 7 #4'S @ 12" SPACING

	APPROVED DATE: <u>January 1, 2011</u> DIRECTOR OF ENGINEERING	STANDARD DRAWING PITOT INSTALLATION	STD. DWG. NO. W-0690