



NOTES:

1. VAULTS WITH H+COVER>4.0' SHALL HAVE ACCESS LADDER. LANDING SHALL HAVE A MIN. CLEAR AREA OF 3' X 3'
2. MANUFACTURERS DESIGN DATA AND DRAWINGS FOR PRECAST CONCRETE VAULT W/BOTTOM SECTION, SHALL BE SUBMITTED AND APPROVED BY W.M.W.D. BEFORE INSTALLATION.
3. PROVIDE GRAVITY FLOW DRAIN PIPE FOR SUMP, OR IF POWER IS AVAILABLE, INSTALL SUMP PUMP WITH APPROPRIATE DRAIN PIPING. MUST DISCHARGE TO PUBLIC STORM DRAIN OF DRAINAGE SWALE WITH DRAINAGE EASEMENT.
4. LATERAL CLEARANCE BETWEEN THE PIPES, VALVES, AND FITTINGS SHALL BE A MINIMUM OF 4' O.D. TO O.D. AND 3' O.D. TO VAULT WALL.

	APPROVED DATE: <u>January 1, 2011</u>  <u>DIRECTOR OF ENGINEERING</u>	STANDARD DRAWING UTILITY VAULT	STD. DWG. NO. W-0700