



NOTE:

1. FOUNDATION FOR DROP SECTION SHALL BE POURED MONOLITHICALLY WITH MANHOLE BASE.
2. ALL APPLICABLE PROVISIONS OF STANDARD MANHOLE DETAIL DRAWING W-1070 SHALL APPLY TO DROP MANHOLE.
3. THIS CONFIGURATION IS ALLOWED ONLY FOR A NEW SEWER CONNECTION TO AN EXISTING MANHOLE, SO THAT THE SLOPE OF THE NEW SEWER PIPE DOES NOT EXCEED 5%.
4. EXISTING MANHOLE MUST BE COMPLETELY COATED WITH ZEBRON OR T-LOK COATING.
5. WEIGHT OF CLEAN-OUT LID MUST NOT BE SUPPORTED BY THE PIPE.

APPROVED DATE: January 1, 2011

Fayth Brandy

DIRECTOR OF ENGINEERING

STANDARD DRAWING
DROP MANHOLE

STD. DWG.
NO.

W-1080

