



SEWER CLEAN OUT

NOTE:

CLEAN OUT LINE TO BE OF THE SAME MATERIAL & SIZE AS SEWER MAIN. THE SEWER MAIN SHALL BE LAID TO THE CLEAN OUT STATION POINT AND INVERT ELEVATION AS SHOWN ON THE PLAN & PROFILE. THE TRENCH FOR THE CLEAN OUT SHALL BE EXCAVATED ONLY TO SUB GRADE WHICH IS THE BOTTOM OF THE SLOPING PIPE AND FITTINGS. SHOULD THE EXCAVATION FOR ANY REASON BE CARRIED BELOW SUB GRADE, IT SHALL BE REFILLED TO SUB GRADE WITH ROCK OR GRAVEL WHICH SHALL BE TAMPED UNTIL FIRM AND UNYIELDING. SHOULD A FIRM AND UNYIELDING FOUNDATION BE UNOBTAINABLE BY THIS METHOD A CONCRETE PIPE CRADLE SHALL BE USED

NOTES:

1. REFER TO STANDARD DRAWINGS OF MANHOLES FOR DETAILS PERTAINING TO MANHOLES ONLY.
2. SEWER MAINS LAID IN THE MANHOLE ARE TO FORM THE INVERT. THE TOP 1/2 Ø OF THE PIPE IS TO BE BROKEN OUT TO A NEAT LINE. BROKEN EDGES SHALL BE PLASTERED SMOOTH WITH CEMENT MORTAR.
3. AS MANY AS 4 - 4" LATERALS MAY FLOW INTO TERMINUS MANHOLE.



APPROVED DATE: January 1, 2011
Joseph Benavides

 DIRECTOR OF ENGINEERING

STANDARD DRAWING
 SEWER CLEAN OUT
 & TERMINUS MANHOLE

STD. DWG.
 NO.
 W-1090