



**CUT IN WYE CONNECTION
FOR EXISTING PVC PIPE
TYPE A**

**CUT IN WYE CONNECTION
FOR EXISTING VCP PIPE
TYPE B**

NOTES:

- 1) REFER TO SECTION 3.0 OF THE SPECIFICATIONS
- 2) CONNECTIONS TO EXISTING SEWER MAINS TO BE MADE BY DISTRICT PERSONNEL IN ACCORDANCE WITH SECTION 3.0 UNLESS OTHERWISE NOTED ON PLANS
- 3) IN NO CASE SHALL CONNECTION BE MADE DIRECTLY ON TOP OF SEWER MAIN
- 4) NO MORE THAN ONE CUT IN WYE WILL BE ALLOWED FOR EACH LENGTH OF EXISTING VCP SEWER MAIN
- 5) FOR SEWER LATERAL INSTALLATION SEE WMWD STD W-1050 & W-1060
- 6) FOR TRENCH BACKFILL SEE WMWD STD W-1540
- 7) MATERIALS SHALL BE SELECTED FROM THE APPROVED MATERIALS LIST

ITEM NO	SIZE AND DESCRIPTION	ITEM NO	SIZE AND DESCRIPTION
1	45° SADDLE WYE WITH GASKET	4	CONCRETE ENCASEMENT
2	STAINLESS STEEL HOSE CLAMPS (2-EACH)	5	EXISTING VCP SEWER MAIN
3	EXISTING PVC SEWER MAIN		



APPROVED DATE: January 1, 2011

Joseph Brandy
DIRECTOR OF ENGINEERING

STANDARD DRAWING

4" AND 6"
SEWER CUT-IN WYE CONNECTIONS

STD. DWG.
NO.

W-1150