



NOTES:

1. THE BARREL DIAMETER OF THE SAMPLING STATION SHALL BE A MINIMUM OF 2" LARGER THAN THE BUILDING DISCHARGE LINE.
2. THE DIAMETER OF THE RISER PIPE SHALL BE 4".
3. THE SAMPLE WYE SHALL BE ACCESSIBLE TO WMWD'S INDUSTRIAL PRETREATMENT PROGRAM REPRESENTATIVE DURING NORMAL WORKING HOURS.
4. THE SAMPLE WYE SHALL NOT BE INSTALLED IN TRAVEL WAYS, UNLESS AUTHORIZED BY WMWD.
5. A FLUSH CAP SHALL BE USED FOR ALL SAMPLE WYES INSTALLED IN FLOOR AREAS.



APPROVED DATE: January 1, 2011

Jay P. Kusko

DIRECTOR OF ENGINEERING

STANDARD DRAWING
Sewer Sample Wye

STD. DWG.
NO.

W-1170