



**NOTES:**

1. ALL PIPE & FITTINGS BETWEEN AND INCLUDING THE STOPS SHALL:
  - A. BE MADE OF BRASS OR BRONZE.
  - B. BE DESIGNED FOR MORE THAN 175 P.S.I. (COLD) WATER WORKING PRESSURE.
2. ALL BARE STEEL OR IRON SHALL BE COATED AND PROTECTED AS PER SPECS. PRIOR TO PLACING BACKFILL.
3. PRESSURE TEST PRIOR TO WRAPPING OR BACKFILLING.
4. CORP STOP, FITTINGS & SERVICE LINE WITHIN 3' OF SADDLE SHALL BE COATED WITH #1170 PRIMER & 20 MIL. MIN. PIPE WRAP PER APPROVED MATERIALS LIST.
5. ALL SERVICE PIPE & TUBING SHALL BE LAID ON A CONSTANT SLOPE UP FROM THE WATER MAIN TO METER. NO DIPS OR POCKETS IN LINE WILL BE PERMITTED.
6. THREAD NOTATION SHOWS THIS: IP=IRON PIPE THREAD
7. METER BOX IS TO BE LOCATED PER STANDARDS OF AGENCY OF LOCAL JURISDICTION. COORDINATE LOCATION ALONG LOT FRONTAGE WITH WESTERN INSPECTOR.
8. METER BOXES SHALL BE ONE-PIECE POLYMER COVER TOUCH READ LID PER APPROVED MATERIALS LIST.
9. CUSTOMER PIPING REQUIRED TO BE BRASS FOR 6' MINIMUM, THREAD PIPE TO FIT LINESETTER, NO JOINTS ALLOWED.
10. MINIMUM 5'-0" SEPARATION BETWEEN SEWER LATERAL AND WATER SERVICE.
11. WHEN METER IS INSTALLED, IT IS TO BE PAINTED APPROVED PURPLE.

**PROTECTED SERVICE**

	APPROVED DATE: <u>January 1, 2011</u>	RECYCLED WATER STANDARD DRAWING <b>RECYCLED WATER SERVICE</b> <b>3/4" AND 1"</b>	STD. DWG. NO.
	 _____ DIRECTOR OF ENGINEERING		