



* EXCEPT IN DIVIDED HIGHWAYS
 * 6'-1/2" WIDTH OF THE CENTRAL MEDIAN.

NOTE:

1. REQUIRED CLEARANCE BETWEEN RECYCLED WATER PIPELINE AND DOMESTIC PIPELINE SHALL BE CONSISTENT WITH CA DEPARTMENT OF HEALTH STANDARDS.
2. FOR ANY DOMESTIC WATER, SEWER AND RECYCLED WATER CROSSINGS, A MINIMUM SEPERATION OF 1' VERTICAL MUST BE MAINTAINED.

	APPROVED DATE: <u>January 1, 2011</u>  <hr/> DIRECTOR OF ENGINEERING	RECYCLED WATER STANDARD DRAWING WATER/SEWER LOCATION	STD. DWG. NO. <hr/> W-1290
---	---	---	-------------------------------