



POUR AGAINST UNDISTURBED OR WELL COMPACTED EARTH 90% MIN.

EMBED IN CONCRETE HOLE TO BE 12" DIA. X 30" DEEP, AT EACH POST.

**NOTES:**

1. PAINT ALL MATERIAL ABOVE GROUND 2 COATS OF SAFETY YELLOW FOR TREATED WATER SYSTEM, OR 2 COATS OF PURPLE FOR RECYCLED WATER SYSTEMS.
2. INSTALL AT ALL AIR VALVE LOCATIONS AND AT DESIGNATED FIRE HYDRANTS, OR OTHER LOCATIONS, AS REQUIRED ON PLANS OR SPECIFICATIONS.



APPROVED DATE: January 1, 2011

*Joseph Henrichs*

DIRECTOR OF ENGINEERING

STANDARD DRAWING  
4" GUARD POSTS

STD. DWG. NO.

W-1520